

FEDERAL CENTER, BLDG. 3
607 HARDESTY
KANSAS CITY, MO

Inspected By: Professional Industrial Hygiene Services

Inspection Date: 15-Dec-1992

Floor

BSMT

Location	Type and Description	Quantity	Is It Asbestos?
S. pipe tunnel	Thermal System Lagging, Condensate return	15 FT	YES
Boiler room, #3 Boil	Thermal System 4" insulation under metal jacket	1400 Sq Ft	YES
S. Pipe tunnel	Thermal System Steam lagging	19 Fittings	Y
Boiler house, #3 bo	Thermal System Lower cylindrical tank insulation	50 Sq Ft	YES
Booiler house/S en	Thermal System Hot water tanks, 3	340 Sq Ft	YES
NW Pipe tunnel	Thermal System Lagging, Condensate return	40 FT	YES
Boiler house	Thermal System Hot water line, lagging	70 FT	YES
NW Pipe tunnel	Thermal System Hot water lagging	80 FT	YES

Boiler room	Thermal System	230 FT	YES
	Lagging, condensate return		

NE room/W tunnel/	Thermal System	100 FT	YES
	Lagging, condensate return		

S. pipe tunnel	Thermal System	6 Fittings	YES
	Cold water fittings		

Boiler house	Thermal System	14 Fittings	YES
	Hot water fittings		

#3 boiler, boiler ho	Thermal System	220 Sq Ft	YES
	Top cylindrical tank insulation		

S. Pipe tunnel	Thermal System	20 FT	YES
	Cold water lagging		

NW Pipe tunnel	Thermal System	40 FT	YES
	Lagging, Condensate return		

Old boiler house	Thermal System	650 FT	YES
	Steam lagging		

Floor

Location	Type and Description	Quantity	Is It Asbestos?
Boiler house, old b	Thermal System	50 Sq Ft	YES
	Mudded insulation, #3 boiler		

Boiler house, old b	Thermal System	50 Sq Ft	YES
	Mudded insulation, #2 boiler		

Boiler house, old b	Thermal System	2200 Sq Ft	YES
	Insulation, inside & doors		
Boiler house, old b	Thermal System	240 Sq Ft	YES
	Breeching ins./Boilers 1 & 2		
OLD BOILER HOU	TSI	21 Fittings	Yes
	HOT WATER FITTINGS		
S. pipe tunnel	Thermal System	15 FT	YES
	Lagging, Condensate return		
Boiler house, old b	Thermal System	150 Sq Ft	YES
	Breeching insulation, #3 boiler		
NW Pipe tunnel	Thermal System	80 FT	Y
	Steam, TSI lagging		
NE room/E Tunnel/	Thermal System	100 FT	YES
	Steam lagging		
Old boiler house	Thermal System	114 Fittings	YES
	Steam fittings		
Upper level, newer	Thermal System	20 Fittings	YES
	Steam lines, fittings		
Upper leve, newer	Thermal System	31 Fittings	YES
	Fittings, condensate return		

Old boiler house	Thermal System	21	Fittings	YES
	Steam (newer), Fittings			

Old boiler house	Thermal System	19	Fittings	YES
	Cold water fittings			

S. Pipe tunnel	Thermal System	30	FT	YES
	Steam lagging			

FEDERAL CENTER, BLDG. 6
607 HARDESTY
KANSAS CITY, MO

Inspected By: Professional Industrial Hygiene Services

Inspection Date: 15-Dec-1992

Floor

002

Location	Type and Description	Quantity	Is It Asbestos?
FAA-LABRATORY	Miscellaneous 12" FLOOR TILE-GREEN W/WHITE STREAKS	0 FT	Y
FAA-STAGING AR	Miscellaneous 12" FLOOR TILE-BEIGE MARBLE UNDER CA	0 FT	Y
WAREHOUSE - S	Thermal System NEWER STEAM/MISSED DURING ABATEMENT	0 FT	Y
FAA-LOANSTOCK	Thermal System STEAM-ABANDONED	50 FT	Y
FAA-LABORATOR	Thermal System ABANDONED STEAM-ABOVE CEILING	30 FT	Y
FAA-TRAINING R	Thermal System STEAM ABANDONED	50 FT	Y
FAA-LABORATOR	Thermal System STEAM	0 FT	Y
FAA-TRAINING R	Thermal System STEAM/ABANDONED	0 FT	Y

FAA-LOANSTOCK	Thermal System	0 FT	Y
	STEAM-ABANDONED		

Floor

EXT			
Location	Type and Description	Quantity	Is It Asbestos?
BUILDING EXTERI	Miscellaneous	0 FT	Y
	CORRUGATED CEMENT ASBESTOS EXTERIOR		

Floor

INT			
Location	Type and Description	Quantity	Is It Asbestos?
NE STAIRWELL	Miscellaneous	0 FT	Y
	MISC CEMENT ASBESTOS PANELS - FIRE BA		

SW OFFICES	Miscellaneous	0 FT	Y
	12" FLOOR TILE-GREEN WWHITE STREAKS		

UNDER NE STAIR	Miscellaneous	0 FT	Y
	MISC CEMENT-ASBESTOS PANELS ON WALLS		

WAREHOUSE INT	Miscellaneous	0 FT	Y
	CEMENT ASBESTOS INTERIOR"DOUBLE LAYE		

FEDERAL CENTER, BLDG. 7
607 HARDESTY
KANSAS CITY, MO

Inspected By: Professional Industrial Hygiene Services

Inspection Date: 15-Dec-1992

Floor

Location	Type and Description	Quantity	Is It Asbestos?
THROUGHOUT B	Thermal System HOT WATER FITTING	0 FT	Y
THROUGHOUT B	Thermal System STEAM SUPPLY LAGGING	300 FT	Y
THROUGHOUT B	Thermal System STEAM SUPPLY FITTINGS	0 FT	Y
THROUGHOUT B	Thermal System CONDENSATE RETURN LAGGING	300 FT	Y
THROUGHOUT B	 CONDENSATE RETURN FITTING	0 FT	Y
ENTIRE BUILDING	Miscellaneous 9X9 FLOOR TILE MED BROWN W/DARK BROW	0 FT	Y
ENTIRE BUILDING	Miscellaneous 12" FLOOR TILE LIGHT BROWN/W BROWN	0 FT	Y
THROUGHOUT B	Thermal System COLD WATER FITTINGS	0 FT	Y

THROUGHOUT B	Thermal System	110	FT	Y
	COLD WATER LAGGING			

TUNNEL	Thermal System	0	FT	Y
	INSULATION DEBRIS ALL OVER FLOOR			

Floor

ESMT

Location	Type and Description	Quantity	Is It Asbestos?	
Crawlspace under	Thermal System	260	FT	YES
	Steam line lagging			

Crawlspace under	Thermal System	25	Fittings	YES
	Steam line fittings			

FEDERAL CENTER, BLDG. 9
607 HARDESTY
KANSAS CITY, MO

Inspected By: Professional Industrial Hygiene Services

Inspection Date: 15-Dec-1992

Floor

002

Location	Type and Description	Quantity	Is It Asbestos?
WAREHOUSE-ALL	Thermal System	65 FT	Y

STEAM-6" & 4"

RESTROOM	Thermal System	3 FT	Y
----------	----------------	------	---

STEAM

RESTROOM	Thermal System	0 FT	Y
----------	----------------	------	---

HOT WATER

WAREHOUSE-ALL	Thermal System	0 FT	Y
---------------	----------------	------	---

STEAM 6" & 4"

RESTROOM	Thermal System	0 FT	Y
----------	----------------	------	---

STEAM

Floor

BSMT

Location	Type and Description	Quantity	Is It Asbestos?
N. SECTION	Thermal System	0 FT	Y

COLD WATER

N. SECTION	Thermal System	650 FT	Y
------------	----------------	--------	---

STEAM

WOMENS RESTR	Miscellaneous	8 FT	Y
--------------	---------------	------	---

8" CEMENT ASBESTOS FLUE PIPE

S. SECTION OF B	Thermal System	0 FT	Y
	HOT WATER - NEW		

S. SECTION-BASE	Thermal System	150 FT	Y
	COLD WATER		

S. SECTION OF B	Miscellaneous	0 FT	Y
	12" FLOOR TILE-TAN W/BROWN SPLOTCHES		

E. SIDE ROOMS-	Miscellaneous	0 FT	Y
	12" CREAM W/LIGHT BROWN		

N. STAIRWELL	Miscellaneous	0 FT	Y
	9" FLOOR TILE-MED. BROWN W/DARK BRN		

S. SECTION OF B	Thermal System	515 FT	Y
	STEAM		

S. SECTION BASE	Thermal System	0 FT	Y
	COLD WATER		

RESTROOMS-S. E	Thermal System	0 FT	Y
	COLD WATER		

S. SECTION OF B	Thermal System	0 FT	Y
	HOT WATER-OLD		

RESTROOMS-S. E	Thermal System	30 FT	Y
	COLD WATER		

N. SECTION	Thermal System	0 FT	Y
CHILLED WATER			

N. SECTION	Thermal System	70 FT	Y
COLD WATER			

N. SECTION	Thermal System	20 FT	Y
CONDENSATE DRAIN LINE			

S. HALF OF BASE	Thermal System	150 FT	Y
CONDENSATE DRAIN LINES			

S. HALF OF BASE	Thermal System	0 FT	Y
CONDENSATE DRAIN LINES			

S. SECTION OF B	Thermal System	75 FT	Y
HOT WATER			

S. HALF OF BASE	Miscellaneous	0 FT	Y
9" FLOOR TILE-MEDIUM BROWN W/DARK BR			

CENTER STAIRW	Miscellaneous	0 FT	Y
12" FLOOR TILE-CREAM W/DARK BROWN&TN			

S. HALF-BASEME	Thermal System	0 FT	Y
CHILLED WATER			

S. SECTION OF B	Thermal System	0 FT	Y
COLD WATER			

S. END OF BLDG.	Miscellaneous	0 FT	Y
12" FLOOR TILE-GRAY W/DARK & WHITE			

S.E. CORNER OF	Miscellaneous	0 FT	Y
9" FLOOR TILE-WHITE W/BLACK STREAKS			

MECHANICAL RO	Thermal System	0 FT	Y
CHILLED WATER TANK-MUDDIED SEAMS&ENDS			

S. BASEMENT, E.	Miscellaneous	0 FT	Y
12" FLOOR TILE-CREAM W/DARK BROWN&TN			

MAIN MECHANIC	Thermal System	0 FT	Y
CHILLED WATER			

S. SECTION OF B	Thermal System	0 FT	Y
STEAM			

N. SECTION	Thermal System	0 FT	Y
STEAM			

RESTROOMS-S. E	Thermal System	0 FT	Y
HOT WATER			

S. END ABOVE E.	Thermal System	0 FT	Y
STEAM-NEWER			

Floor

EXT

Location	Type and Description	Quantity	Is It Asbestos?
Building exterior	Miscellaneous	960 Sq Ft	YES
Cement asbestos ext. window panels			

Floor

G	Location	Type and Description	Quantity	Is It Asbestos?
	GROUND FLOOR/	Thermal System STEAM	290 FT	Y
	GROUND FLOOR-	Thermal System CONDENSATE RETURN	0 FT	Y
	MENS RESTROO	Miscellaneous CEMENT ASBESTOS FLUE/VENT PIPE	5 FT	Y
	GROUND FLOOR/	Thermal System STEAM 6" & 4"	0 FT	Y
	GROUND FLOOR-	Thermal System CHILLED WATER-6"	0 FT	Y
	GROUND FLOOR-	Thermal System CONDENSATE RETURN 4"	37 FT	Y
	WEATHER SERVI	Thermal System HOT WATER, ABANDONED, 10 TO NW RESTRMS	0 FT	Y
	7 + 11	Miscellaneous 12" FLOOR TILE-LIGHT TAN W/MED. BRWN	0 FT	Y
	GROUND FLOOR	Thermal System CONDENSATE DRAIN LINE	120 FT	Y
	14-WEATHER SE	Miscellaneous 12" FLOOR TILE-LIGHT BROWN W/BROWN &	0 FT	Y

NEW EQUIPMENT	Miscellaneous	0 FT	Y
	12" FLOOR TILE-BLUE, TAN & BROWN MARB		
GROUND FLOOR-	Thermal System	0 FT	Y
	CONDENSATE DRAIN LINE		
S. AND MIDDLE S	Miscellaneous	0 FT	Y
	12" FLOOR TILE-CREAM W/MED BROWN FIN		
WEATHER SERVI	Thermal System	145 FT	Y
	HOT WATER-ABANDONED 10 TO NW RESTRMS		

FEDERAL CENTER, BLDG. 10
607 HARDESTY
KANSAS CITY, MO

Inspected By: Professional Industrial Hygiene Services

Inspection Date: 15-Dec-1992

Floor

002

Location	Type and Description	Quantity	Is It Asbestos?
WAREHOUSE AR	Thermal System STEAM	0 FT	Y
WAREHOUSE AR	Thermal System STEAM	30 FT	Y
WAREHOUSE AR	Thermal System ROOF DRAINS	0 FT	Y

Floor

BSMT

Location	Type and Description	Quantity	Is It Asbestos?
WAREHOUSE AR	Thermal System STEAM	520 FT	Y
TUNNEL BETWEE	Thermal System STEAM	65 FT	Y
WAREHOUSE AR	Thermal System STEAM	0 FT	Y
MENS RESTROO	Thermal System HOT WATER-NEWER	0 FT	Y
MENS RESTROO	Thermal System COLD WATER	0 FT	Y

SUBSTATION	Miscellaneous	15 FT	Y
	4" - CONDUIT INSULATION		

MENS RESTROO	Miscellaneous	8 FT	Y
	CEMENT ASBESTOS FLUE PIPE		

MENS RESTROO	Thermal System	5 FT	Y
	CONDENSATE RETURN		

WAREHOUSE AR	Thermal System	0 FT	Y
	HOT WATER		

TUNNEL BETWEEN	Thermal System	0 FT	Y
	HOT WATER		

WAREHOUSE AR	Thermal System	608 FT	Y
	HOT WATER		

TUNNEL BETWEEN	Thermal System	65 FT	Y
	HOT WATER		

MENS RESTROO	Thermal System	0 FT	Y
	CONDENSATE RETURN		

WAREHOUSE AR	Thermal System	0 FT	Y
	NEWER STEAM		

Floor

EXT

Location	Type and Description	Quantity	Is It Asbestos?
BLDG. EXTERIOR	Miscellaneous	0 FT	Y
	EXTERIOR WINDOW PANELS		

Floor

C

Location	Type and Description	Quantity	Is It Asbestos?
E.SIDE, MENS RE	Thermal System CONDENSATE RETURN	8 FT	Y
E.SIDE WAREHO	Thermal System STEAM	64 FT	Y
OLD KITCHEN	Thermal System STEAM	0 FT	Y
E SIDE, MENS RE	Thermal System STEAM	0 FT	Y
OLD KITCHEN & O	Thermal System STEAM	42 FT	Y
E SIDE MENS RE	Thermal System CONDENSATE RETURN	0 FT	Y
E. SIDE MENS RE	Thermal System COLD WATER	0 FT	Y
E. SIDE WAREHO	Thermal System STEAM	0 FT	Y
E. SIDE MENS RE	Thermal System STEAM	3 FT	Y
E SIDE MENS RE	Thermal System CEMENT ASBESTOS FLUE PIPE	4 FT	Y

NW CORNER OFF	Thermal System	0 FT	Y
	HOT WATER		

E. SIDE, MENS RE	Thermal System	25 FT	Y
	COLD WATER		

OLD KITCHEN	Thermal System	0 FT	Y
	HOT WATER		

OLD KITCHEN	Thermal System	0 FT	Y
	COLD WATER		

GROUND FLOOR	Miscellaneous	0 FT	Y
	9" FLOOR TILE-DARK BROWN W/LITE BROWN		

GROUND FLOOR	Miscellaneous	0 FT	Y
	9" FLOOR TILE-DARK BROWN W/LITE BRWN		

E. SIDE MENS RE	Thermal System	0 FT	Y

E. SIDE MENS RE	Thermal System	45 FT	Y
	HOT WATER		

E. SIDE MENS RE	Thermal System	0 FT	Y
	CONDENSATE RETURN		

WAREHOUSE BA	Thermal System	0 FT	Y
	DEBRIS FROM FITTINGS		

E. SIDE,N. CENTE	Miscellaneous	0 FT	Y
12" TAN FLOOR TILE			

WAREHOUSE AR	Thermal System	0 FT	Y
HOT WATER			

Floor

Location	Type and Description	Quantity	Is It Asbestos?
BLDG. EXTERIOR,	Miscellaneous	0 FT	Y
CEMENT ASBESTOS EXTERIOR PANELS			

FEDERAL CENTER, BLDG. 11
607 HARDESTY
KANSAS CITY, MO

Inspected By: Professional Industrial Hygiene Services

Inspection Date: 15-Dec-1992

Floor

002

Location	Type and Description	Quantity	Is It Asbestos?
V-3,W-3 BAY	Thermal System AIRWELL LAGGING HANGING FROM LARGER	6 FT	Y
S. SIDE WHSE AR	Thermal System NEWER STEAM	0 FT	Y
MAINTENANCE O	Thermal System NEWER STEAM	0 FT	Y
N. END OPEN WH	Thermal System NEW STEAM	0 FT	Y
MAIN MECHANIC	Thermal System CHILLED WATER	0 FT	Y
WELDING SHOP/B	Thermal System COLD WATER	5 FT	Y
S. SIDE WAREHO	Thermal System COLD WATER	0 FT	Y
S. SIDE WAREHO	Thermal System STEAM	220 FT	Y

N. END OPEN WH	Thermal System	12 FT	Y
	STEAM		

MAINTANENCE O	Miscellaneous	0 FT	Y
	9" FLOOR TILE-GREEN WWHITE & BLACK		

S.SIDE WAREHO	Thermal System	0 FT	Y
	STEAM		

N.END AREA WAR	Thermal System	0 FT	Y
	STEAM		

MAIN MECHANIC	Miscellaneous	0 FT	Y
	9" FLOOR TILE-GREEN WWHITE & BLACK		

N. END OPEN WH	Thermal System	0 FT	Y
	COLD WATER		

S. SIDE WAREHO	Thermal System	50 FT	Y
	COLD WATER		

MAIN MECHANIC	Thermal System	0 FT	Y
	CITY WATER		

MAIN MECHANIC	Thermal System	0 FT	Y
	CHILLED INSULATION JACKET		

S.SIDE WAREHO	Miscellaneous	0 FT	Y
	MISC CEMENT ASBESTOS WALLBOARD		

WELD SHOP/BLU	Thermal System	0 FT	Y
	COLD WATER		

WELDING SHOP/B	Thermal System	0 FT	Y
	COLD WATER		

WELD SHOP/BLU	Miscellaneous	16 FT	Y
	6" CEMENT ASBESTOS VENT PIPES		

WELDING SHOP/B	Miscellaneous	0 FT	Y
	CEMENT ASBESTOS WALL PARTITIONS		

Floor

BSMT

Location	Type and Description	Quantity	Is It Asbestos?
ABOVE WOMENS	Thermal System	17 FT	Y
	STEAM		

TUNNEL BETWEEN	Thermal System	248 FT	Y
	STEAM - 12" & 8"		

WHSE AREA(VSM	Thermal System	0 FT	Y
	HOT WATER		

ABOVE MENS RE	Thermal System	12 FT	Y
	FLOOR DRAINS		

OLD RESTROOM/	Miscellaneous	15 FT	Y
	6" CEMENT ASBESTOS FLOE		

ABOVE WOMENS	Thermal System	0 FT	Y
	STEAM		

OLD RESTROOM -	Thermal System	17 FT	Y
	STEAM-LARGE 10-12"		
MECH. ROOM P-Q	Thermal System	0 FT	Y
	STEAM - 4"		
DMA-P TO R EAS	Thermal System	276 FT	Y
	FLOOR DRAINS OR ROOF DRAINS		
WHSE (VSMC)P2-	Thermal System	1035 FT	Y
	STEAM-LARGE 10-12" & 6"		
OLD RESTROOM/	Thermal System	0 FT	Y
	HOT WATER		
DMA-ALL	Thermal System	365 FT	Y
	STEAM-8" & 4"(COVERED W/PLASTIC SLVS		
MECH ROOM-P-Q,	Thermal System	0 FT	Y
	CONDENSATE RETURN		
DMA - P TO R, EA	Thermal System	0 FT	Y
	FLOOR DRAINS		
WHSE (VSMC) P2-	Thermal System	0 FT	Y
	STEAM-LARGE 10-12" & 6"		
MECH. ROOM-P T	Thermal System	15 FT	Y
	STEAM - 4"		

OLD RESTROOM-	Thermal System	30 FT	Y
	CONDENSATE RETURN		
OLD RESTROOM/	Thermal System	0 FT	Y
	STEAM - LARGE 10-12"		
WRHSE(VSMC)P2	Thermal System	0 FT	Y
	COLD WATER		
WAREHOUSE US	Thermal System	551 FT	Y
	CONDENSATE RETURN		
MECH ROOM-P T	Thermal System	15 FT	Y
	CONDENSATE RETURN		
WAREHOUSE US	Thermal System	0 FT	Y
	CONDENSATE RETURN		
OLD RESTROOM-	Thermal System	0 FT	Y
	CONDENSATE RETURN		
TUNNEL BETWEE	Thermal System	0 FT	Y
	HOT WATER		
TUNNEL BETWEE	Thermal System	145 FT	Y
	HOT WATER		
OLD RESTROOM/	Thermal System	0 FT	Y
	HOT WATER TANK-ABANDONED		

WHSE(VSMC) NO	Thermal System	0 FT	Y
	STEAM - NEWER		

TUNNEL BETWEE	Thermal System	0 FT	Y
	STEAM - 12" & 8"		

DMA-ALL	Thermal System	0 FT	Y
	STEAM-8" & 4" (COVERED W/PLASTIC SLV)		

Floor

Location	Type and Description	Quantity	Is It Asbestos?
EXTERIOR WIND	Miscellaneous	0 FT	Y
	CEMENT ASBESTOS EXTERIOR WINDOW PANS		

S. SIDE BLDG EX	Thermal System	0 FT	Y
	STEAM FITTING		

S. SIDE BLDG EX	Thermal System	150 FT	Y
	STEAM		

Floor

Location	Type and Description	Quantity	Is It Asbestos?
WAREHOUSE AR	Thermal System	0 FT	Y
	COLD WATER		

RESTROOM BY V.	Thermal System	0 FT	Y
	COLD WATER		

LOADING DOCK-V	Thermal System	0 FT	Y
	COLD WATER		

DMA	Thermal System	1043	FT	Y
STEAM (LARGE & SMALL)				
RESTROOM BY V	Thermal System	20	FT	Y
STEAM				
WAREHOUSE AR	Thermal System	70	FT	Y
STEAM - 4"				
DMA-SUPPLY RO	Thermal System	0	FT	Y
DEBRIS FROM PIPE INSULATION-TRIMMING				
LOADING DOCK-V	Thermal System	0	FT	Y
HOT WATER				
SMALL LOBBY W	Miscellaneous	0	FT	Y
12" FLOOR TILE-OLIVE & CREAM MARBLE				
WOMENS RESTR	Miscellaneous	0	FT	Y
12" FLOOR TILE-TAN & CREAM MARBLE				
LOADING DOCK-U	Thermal System	40	FT	Y
CONDENSATE DRAIN LINE LAGGING				
LOADING DOCK-V	Thermal System	170	FT	Y
STEAM				
SECURITY OFFIC	Thermal System	0	FT	Y
CHILLED WATER				

RESTROOM BY U	Thermal System	0 FT	Y
	CONDENSATE RETURN		
OPEN WHSE BAY	Thermal System	0 FT	Y
	STEAM FITTINGS		
RESTROOM BY U	Thermal System	0 FT	Y
	STEAM-4"		
LOADING DOCK A	Thermal System	0 FT	Y
	STEAM		
WAREHOUSE AR	Thermal System	0 FT	Y
	STEAM		
OPEN WAREHOU	Thermal System	4 FT	Y
	CONDENSATE RETURN		
RESTROOM BY U	Thermal System	0 FT	Y
	CONDENSATE RETURN		
OPEN WAREHOU	Thermal System	0 FT	Y
	CONDENSATE RETURN		
OPEN WHSE BAY	Thermal System	0 FT	Y
	NEWER STEAM		
DMA-10	Miscellaneous	0 FT	Y
	12" CEILING TILE-2 SIZES OF CIRCULAR		

LOADING DOCK -	Thermal System	0 FT	Y
	CHILLED WATER		

MENS RESTROO	Thermal System	0 FT	Y
	HOT WATER		

DMA	Thermal System	0 FT	Y
	CHILLED WATER		

VACANT OFFICES	Miscellaneous	0 FT	Y
	9" FLOOR TILE-GRAY W/ORANGE UNDER CA		

DMA-S.END, CEN	Thermal System	0 FT	Y
	CONDENSATE DRAIN LINE FITTINGS		

LOADING DOCK-U	Thermal System	0 FT	Y
	CONDENSATE DRAIN LINE FITTINGS		

DMA-CENTER CO	Thermal System	0 FT	Y
	PIPE INSULATION DEBRIS FROM PIPE		

DMA-MECHANICA	Thermal System	0 FT	Y
	TSI FITTING DEBRIS ON FLOOR		

OPEN WAREHOU	Miscellaneous	0 FT	Y
	9" FLOOR TILE-GREEN W/WHITE STREAKS		

DMA-ALL	Miscellaneous	0 FT	Y
	9" FLOOR TILE-GREEN W/WHITE		

OPEN WHSE BAY	Thermal System	82 FT	Y
	STEAM - 4" & 6"		

DMA-14	Thermal System	0 FT	Y
	TSI DEBRIS-MAGNESIA PIPE INSULATION		

RESTROOM BY V	Thermal System	0 FT	Y
	HOT WATER		

OPEN WAREHOU	Thermal System	0 FT	Y
	CHILLED WATER FITTINGS		

Floor

Location	Type and Description	Quantity	Is It Asbestos?
ROOF-S. ELEVAT	Miscellaneous	0 FT	Y
	CEMENT ASBESTOS WINDOW PANEL		

S.E. COOLING TO	Miscellaneous	0 FT	Y
	CEMENT ASBESTOS COOLING TOWER FINS		

FEDERAL CENTER, BLDG. 13
607 HARDESTY
KANSAS CITY, MO

Inspected By: Professional Industrial Hygiene Services

Inspection Date: 15-Dec-1992

Floor

G

Location	Type and Description	Quantity	Is It Asbestos?
DMA	Thermal System STEAM	0 FT	Y
DMA	Thermal System CONDENSATE RETURN	85 FT	Y
DMA	Thermal System CONDENSATE RETURN	0 FT	Y
SUBSTATION INT	Miscellaneous MISC CEMENT ASBESTOS ENCLOSURE PANEL	0 FT	Y
SUBSTATION INT	Miscellaneous CEMENT ASBESTOS CORRUGATED CEILING P	0 FT	Y
SUBSTATION INT	Miscellaneous WOVEN 2" WIDE ASBESTOS CABLE INSULAT	180 FT	ASSUMED